

To Save Life & Property is our Motto

Sec. 15-A : 2284444, 101

N.L.T. : 2412668

Bellabgarh : 2305744

Sec. 31 : 2275886

HARYANA FIRE & EMERGENCY SERVICES

FARIDABAD

No Objection Certificate (Under 15 Mtr. Height)

Ref. No. FS/2018/ 981/BLB

Dated 19/4/18

Certified that M/s. AGGARWAL PUBLIC SCHOOL [C.B.S.E.]

SECTOR- 3, URBAN ESTATE, FARIDABAD has made Satisfactory

Fire Safety arrangements as per requirement, hence this office has no objection towards running of this SCHOOL from fire safety Point of view, with the condition of keeping trained staff, fire fighting

system tested during inspection shall always be available in good working condition. During inspection,

Any lapses & non- functioning of fire fighting system will be at the sole responsibility of the

owner / management. The above certificate can be cancelled at any time. This certificate does permit to

violate any laws of the land, building NOC from pollution control board and permission from other

concerned authorities. The validity of this certificate is five years from 19/4/18 to 18/4/23

before expiry of this period you have to get renewed this NOC from this office.

[Signature]
Sr. Fire Officer
Fire Station Office
Sec-15A, Faridabad

From Fire Station Officer
Fire Station Sec 15A
To M/s AGGARWAL PUBLIC SCHOOL
Sector 3 Faridabad 121001
Memo No. FS/2022/182 dated : 05/09/2022

Subject : Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at Sector 3 Faridabad 121001 of AGGARWAL PUBLIC SCHOOL :

Reference your Transaction Id 030152223001024 dated: 12/07/2022 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Faridabad. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
A	GROUND + 2	13.926	3374.38
Tower Name	Basement Level	Basement Area	Basement Remarks
	01	242.00	

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

Remarks:- ok



Assistant Divisional Fire
Officer

Fire Station Sec 15A

Exercising the power of Director, Fire Services, Haryana



Digitally signed by Satyavan
Date: 2022.09.05 15:56:37
+05:30
Reason: Digital Verification



Scanned with OKEN Scanner

From Fire Station Officer
Fire Station Sec 15A
To M/s AGGARWAL PUBLIC SCHOOL
Sector 3 Faridabad 121001
Memo No. FS/2022/182 dated : 05/09/2022

ADF-0/2022/F2292/279 Date-5-9-22

Subject : Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B-Educational Building at Sector 3 Faridabad 121001 of AGGARWAL PUBLIC SCHOOL :

Reference your Transaction Id 030152223001024 dated: 12/07/2022 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Faridabad, .The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
A	GROUND + 2	13.926	3374.38
Tower Name	Basement Level	Basement Area	Basement Remarks
	01	242.00	

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

Remarks:- ok



Assistant Divisional Fire
Officer

Fire Station Sec 15A

Exercising the power of Director, Fire Services, Haryana

Rachne
PRINCIPAL
AGGARWAL PUBLIC SCHOOL
SECTOR-3, FARIDABAD



Digitally signed by Satyavan
Date: 2022.09.05 15:56:37
+05:30
Reason: Digital Verification